

LNO-TST07A-00F

LANIOL VDE Voltage Tester

GS-geprüft 3 x 0,5 mm Klinge / 150 mm

GS-mark 3 x 0,5 mm blade / 150 mm



Technische Daten / Technical Data

Klingengröße (Schlitz) Blade size (slot)	3 x 0,5 [mm]	Nennspannung Nominal voltage	125 - 250 [VAC] 50 - 500 [Hz]
Indikator für Spannung Indicator for voltage	Glimmlampe Glow lamp	Indikator Farbe Indicator colour	Signalorange Signal orange
Produktnorm Product norm	DIN VDE 0680-6	Größe Size	Ø 22 x 1570 [mm] Ø 0,87 x 5,91 [in]
Betriebstemperatur Operating temperature	+10 ... +50 [°C] +50 ... +122 [°F]	Gewicht Weight	21 [g] 0,05 [lb]
Isolationsmaterial Isolating Material	ABS	Materialfarbe Coat colour	Gelb Yellow



Der LANIOL VDE Phasenprüfer liegt bequem in der Hand und schützt vor unabsichtliches abrutschen der Hand, wie bei Werkzeugen in der DIN EN IEC 60900 üblich beschrieben, mit seiner 5mm umlaufende Griffbegrenzung. Für das Öffnen der Federzugklemme in allen CONLOX® GridClamps ist er bestens geeignet. VDE 0680-6 geprüft inkl. Geprüfte Sicherheit (GS-Zeichen).

The LANIOL VDE voltage tester sits comfortably in the hand and protects against unintentional slipping of the hand, as commonly described for tools in DIN EN IEC 60900, with its 5 mm circumferential grip limit. It is ideally suited for opening the spring clamp in all CONLOX® GridClamps. VDE 0680-6 tested incl. tested safety (GS mark).

Artikel-Nr. / Article-no.:

St. / pcs.	GTIN
1	42607289 80558

ZolltarifNr.: 90303370

26

Rev. 1.0 – 12 / 2023